

Display energy certificate (DEC)



HM Government

Folksworth C of E School
Apreece Road
Folksworth
PETERBOROUGH
PE7 3TY

Operational rating

C

Certificate number: 0015-7220-3147-4952-3530

Valid until: 29 July 2033

Total useful floor area: 639 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C	60 C	
76-100	D		
----- 100 -----			
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	51.83	11.19
Typical energy use (kWh/m ² /year)	40	150.15
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
July 2023	60 C
April 2013	102 E

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
July 2023	18	1	0
April 2013	25	12	0

Assessment details

Assessor's name	Ryan Spray
Employer/Trading name	CC Ltd
Employer/Trading address	164A Derby Road, Stapleford, Nottingham NG9 7AY
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	18 September 2023
Nominated date	30 July 2023